


Test Report


Customer		Job ID	Timed Test - Multiple
----------	--	--------	-----------------------

Device Details			
Device Under Test			
Manufacturer			


Test Result				
Test ID	Test Voltage/Current	Resistance t1	Resistance t2	PI/DAR
Test Point 1	500V	35.51GΩ	-	-
Test Point 2	500V	49.41GΩ	-	-
Test Point 3	500V	15.95GΩ	-	-
Test Point 4	500V	16.13GΩ	-	-
Test Point 5	500V	16.23GΩ	-	-
Test Point 6	500V	16.30GΩ	-	-




Test ID = Test Point 1 Test Voltage/Current = 500V IRt1 = 35.51GΩ IRt2 = - PI/DAR = -




Test ID = Test Point 2 Test Voltage/Current = 500V IRt1 = 49.41GΩ IRt2 = - PI/DAR = -




Test ID = Test Point 3 Test Voltage/Current = 500V IRt1 = 15.95GΩ IRt2 = - PI/DAR = -



Test ID = Test Point 4 Test Voltage/Current = 500V IRt1 = 16.13GΩ IRt2 = - PI/DAR = -



Test ID = Test Point 5 Test Voltage/Current = 500V IRt1 = 16.23GΩ IRt2 = - PI/DAR = -



Test ID = Test Point 6 Test Voltage/Current = 500V IRt1 = 16.30GΩ IRt2 = - PI/DAR = -

Remarks:

Philips SmartPanel 2.0 RC160V LED25S/840 PSU W60L60 CAU P/N: 911401501121 S/N:

S01ME55F40-0002 Date of Manufacture: 25/05/2015

Resistances > 1Mohm on all tests - goughlui.com

Overall Judgment	OK ()	Not OK ()
------------------	--------	------------

TESTED BY		DATE	
VERIFIED BY		DATE	